
# **COVER SHEET**



### SECURITIES AND EXCHANGE COMMISSION

### SEC FORM 17-C CURRENT REPORT UNDER SECTION 17 OF THE SECURITIES REGULATION CODE AND SRC RULE 17.2(c) THEREUNDER

1. March 9, 2018

Date of Report

 2. SEC Identification No.: <u>91447</u>
 3. BIR Tax Identification No.: <u>000-190-324-000</u>

## 4. SEMIRARA MINING AND POWER CORPORATION

Exact name of issuer as specified in its charter

5. <u>Philippines</u> Province, country or other jurisdiction of incorporation 6. (SEC Use Only) Industry Classification Code:

> (Outstanding) 4,256,129,420

7. <u>2/F, DMCI Plaza, 2281 Chino Roces Avenue, Makati City</u> Address of principal office <u>1231</u> Postal Code

- 8. <u>(632) 888-3000/3055 Fax No. (632) 888-3955</u> Issuer's telephone number, including area code
- 9. <u>N.A.</u> Former name or former address, if changed since last report
- 10. Securities registered pursuant to Sections 8 and 12 of the SRC or Sections 4 and 8 of the RSA

   <u>Title of Each Class</u>

   Number of Shares of Common Stock

### **Common Shares**

11. Indicate the item numbers reported herein: Item 9.

Please be informed that Southwest Luzon Power Generation Corporation (SLPGC), a wholly-owned subsidiary of Semirara Mining and Power Corporation (the "Corporation"), operating the 2x150MW Coal-Fired (Circulating Fluidized Bed) Thermal Power Plant located adjacent to Sem-Calaca Power Corporation's (SCPC) power plant in Calaca, Batangas has reported that Unit 1 of its 2x150MW power units (or Unit 3 of Calaca Power Plant Complex) was put down for unplanned outage since March 6, 2018, due to observed abnormal vibration of the equipment. Detailed inspection of the unit will be done immediately. While, its power unit Unit 2 (150MW) is currently undergoing regular planned maintenance outage and target unit on line is last week of March 2018.

Also, Unit 1 of Sem-Calaca Power Corporation (SCPC), another wholly-owned subsidiary of the Corporation operating the 2x300MW Coal-Fired Thermal Power Plant in Calaca, Batangas is also undergoing an unplanned outage until March 12, 2018 to give way to boiler slags removal. While, SCPC's Unit 2 is also currently undergoing a planned outage, to include the thorough assessment/inspection of the unit prior to the final phase of the rehabilitation (life extension program) in 2019. Unit 2 is expected to be back online by end of the month.

Both SLPGC and SCPC has still allowable outage, hence, not incurring any replacement power.

2

### **SIGNATURES**

Pursuant to the requirements of the Securities Regulation Code, the issuer has duly caused this report to be signed on its behalf by the undersigned thereunto duly authorized.

Issuer	:	Semirara Mining and Power Corporation
Signature and Title	:	JOHN R. SADULLO VP-Legal & Corporate Secretary
Date	:	March 9, 2018